Certificate of Compliance

Certificate Number(s):

UL-US-26116873-0

Report Reference:

E520702-20260928

Issue Date:

2026-10-09

ABD 1000764507 EN Version: - Status: RL (released | freigegeben) printed: 15.10.2026

Issued to:

Burkert Werke GmbH & Co. KG
Christian-Buerkert-Strasse 13-17, Ingelfingen, 74653, DE

This certificate confirms that representative samples of:

QUZW - Process Control Equipment for Use in Hazardous Locations

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL 121201, 9th Ed., Issue Date: 2017-09-15, Revision Date: 2021-04-01

Additional Information:
See UL Product iQ® at https://iq.ulprospector.com for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2026 UL LLC. All rights reserved.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-US-26116873-0
Report reference: E520702-20260928
Issue Date: 2026-10-09

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Class I, Division 2, Group A, B, C and D, Class II, Division 2, Group F and G, Class III, Electromotive actuators

Model(s): AE33-AG2 *AE33- followed by 2 letters:*
"AE33" = digit 1 to 4 = Series designation.
"S" = digit 5 = Control Function, "S" (ON / OFF), "R" (Positioner)
"D" = digit 6 = Valve type, "A" (angle seat valve), "G" (globe seat valve), "D" (diaphragm valve).

ABD 1000764507 EN Version: - Status: RL (released | freigegeben) printed: 15.10.2026

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2026 UL LLC. All rights reserved.
Form-ULID-019496 – ver 1.0

Certificate of Compliance

Certificate Number(s):

UL-CA-2685937-0

Report Reference:

E520702-20260928

Issue Date:

2026-10-09

Issued to:

Burkert Werke GmbH & Co. KG
Christian-Buerkert-Strasse 13-17, Ingelfingen, 74653, DE

This certificate confirms that representative samples of:

QUZW7 - Process Control Equipment for Use in Hazardous Locations Certified for Canada

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

CSA C22.2 NO. 213-17, 3rd Ed., Issue Date: 2017-09-15, Revision Date: 2021-04-01

Additional Information:
See UL Product iQ® at https://iq.ulprospector.com for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2026 UL LLC. All rights reserved.

ABD 1000764507 EN Version: - Status: RL (released | freigegeben) printed: 15.10.2026

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-CA-2685937-0
Report reference: E520702-20260928
Issue Date: 2026-10-09

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Class I, Division 2, Group A, B, C and D, Class II, Division 2, Group F and G, Class III, Electromotive actuators

Model(s): AE33-AG2 *AE33- followed by 2 letters:*
"AE33" = digit 1 to 4 = Series designation.
"S" = digit 5 = Control Function, "S" (ON / OFF), "R" (Positioner)
"D" = digit 6 = Valve type, "A" (angle seat valve), "G" (globe seat valve), "D" (diaphragm valve).

ABD 1000764507 EN Version: - Status: RL (released | freigegeben) printed: 15.10.2026

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2026 UL LLC. All rights reserved.
Form-ULID-019496 – ver 1.0