


BVS 13 ATEX E104X
BVS 13 ATEX E087X

Type 8697

Pneumatic Control Unit with ATEX approval
Pneumatische Ansteuerung mit ATEX-Zulassung
Unité de commande pneumatique avec mode de protection ATEX



Additional Instructions

Zusatzanleitung
Instruction supplémentaire



We reserve the right to make technical changes without notice.
Technische Änderungen vorbehalten.
Sous réserve de modifications techniques.

© Bürkert Werke GmbH & Co. KG, 2012 - 2019

Operating Instructions 1902/04_EU-ml_00810359 / Original DE

1	ADDITIONAL INSTRUCTIONS.....	4
1.1	Definition of terms / abbreviation.....	4
2	SYMBOLS.....	4
3	AUTHORIZED USE.....	5
3.1	Restrictions.....	5
3.2	Identification (V code) Pxx.....	5
4	PARTICULAR SAFETY INSTRUCTIONS.....	6
4.1	Instructions on operation in an explosion-risk (Ex) area... 7	
4.2	Installation locking wire for PE99 and PX03.....	10
4.3	Adaption set - installation note.....	10
4.4	Explosion protection approval.....	12

1 ADDITIONAL INSTRUCTIONS

The additional instructions for the use in potentially explosive environments describe the entire life cycle of the device. Keep these instructions in a location which is easily accessible to every user and make these instructions available to every new owner of the device.

Important safety information.

Read the additional instructions carefully and thoroughly. Study in particular the chapters entitled *Particular safety instructions* and *Authorized use*.

- ▶ The additional instructions must be read and understood.

The additional instructions describe safety instructions and information for the use of the pneumatic control unit in a potentially explosive environment.

All other descriptions and information can be found in the operating instructions of the device for the Type 8697.



The operating instructions can be found on the Internet at:
www.buerkert.com

1.1 Definition of terms / abbreviation

In these instructions, the term "device" always refers to the pneumatic control unit Type 8697.



In these instructions, the abbreviation "Ex" always refers to "potentially explosive".

2 SYMBOLS

The following symbols are used in these instructions.



DANGER!

Warns of an immediate danger.

- ▶ Failure to observe the warning will result in a fatal or serious injury.



WARNING!

Warns of a potentially dangerous situation.

- ▶ Failure to observe the warning may result in a serious or fatal injury.



CAUTION!

Warns of a possible danger.

- ▶ Failure to observe this warning may result in a moderate or minor injury.

NOTE!

Warns of damage to property.



Important tips and recommendations.



Refers to information in these instructions or in other documentation.

- ▶ Designates instructions for risk prevention.
- Designates a procedure which you must carry out.

3 AUTHORIZED USE

Incorrect use of the pneumatic control unit Type 8697 can be dangerous to people, nearby equipment and the environment.

- ▶ The device is designed to be mounted on pneumatic actuators of process valves for the control of media.
The device was designed for the use in
 - **Type 8697 PX03:**
Explosion group II, category 3G Ex nA, T4 and explosion group II, category 3D Ex tc, IP65/67, T135°C
 - **Type 8697 PE99:**
Explosion group II, category 2G Ex ia, T4 and explosion group II, category 2D Ex ia, IP64, T135°C
 - **Type 8697 PE51:**
Explosion group II, category 2G Ex ia, T4
(see information listed on the sticker for the approval).
- ▶ The device is mounted onto a pneumatic actuator of a process valve. The process valve and the actuator must have at least the Ex approval of the pneumatic control unit.
- ▶ During use observe the admissible data, the operating conditions and conditions of use specified in the contract documents, operating instructions and on the type label
 - of the pneumatic control unit Type 8697 and
 - the process valve.
- ▶ Use the device only in conjunction with third-party devices and components recommended and authorized by Bürkert.
- ▶ Correct transportation, storage and installation, as well as careful use and maintenance are essential for reliable and faultless operation.
- ▶ Use the device only for its intended purpose.

3.1 Restrictions

If exporting the system/device, observe any existing restrictions.

3.2 Identification (V code) Pxxx

The identification (V code) PX03, PE99 or PE51 is on the type label of the device.




Fig. 1: Example of type label

4 PARTICULAR SAFETY INSTRUCTIONS



DANGER!

Risk of explosion when removing the electric circular plug.

- ▶ Secure cable connections, which use circular plugs, with suitable locking clips.
For example: EXCLIP, FA. Phoenix Contact, Type SAC-M12-EXCLIP-M, Art. no. 1558988 or Type SAC-M12-EXCLIP-F, Art. no. 1558991 or locking clip, FA. ESCHA, M12 x 1, Art. no. 8040501.
- ▶ Remove electric circular plug only after the power supply has been disconnected.

Risk of explosion when opening the device.

- ▶ Open device only when no Ex atmosphere is present.
- ▶ During the installation and setting of the micro switches, no Ex atmosphere may be present.
- ▶ Prior to start-up, secure the transparent cap against being opened without tools by using the enclosed locking wire.

Risk of explosion due to electrostatic discharge.

In the event of a sudden discharge from electrostatically charged devices or individuals, there is a risk of an explosion in the explosion-risk area.

- ▶ Take suitable measures to ensure that no electrostatic discharges can build up in the explosion-risk area.
- ▶ Clean the device surface by gently wiping it with a damp or anti-static cloth only.



DANGER!

To prevent the risk of explosion, observe not only the safety instructions in the operating instructions for operation in the explosion-risk area, but also the following:

- ▶ Observe information on temperature class, ambient temperature, degree of protection and voltage on the approval sticker.
- ▶ Do not use devices in areas where there is gas or dust with a lower ignition temperature than indicated on the approval sticker.
- ▶ Installation, operation and maintenance may be performed by qualified technicians only.
- ▶ Observe the applicable safety regulations (also national safety regulations) as well as the general rules of technology for construction and operation.
- ▶ Do not repair the device yourself, but replace it with an equivalent device.
- ▶ Repairs may be performed by the manufacturer only.
- ▶ Do not expose the device to any mechanical and/or thermal loads which will exceed the limits described in the operating instructions.
- ▶ Use only cable and line entry points which have been approved for the respective application area and which have been screwed into place according to the associated installation instructions.
- ▶ The cable glands shall only be used for fixed installations.
- ▶ Close all unnecessary cable glands with lock screws approved for the explosions area.
- ▶ The required degree of protection (min. IP64) is only guaranteed in connection with suitable adaption sets. All pneumatic and electrical connections must be equipped with suitable connectors.

4.1 Instructions on operation in an explosion-risk (Ex) area

4.1.1 Safety instructions

For operation in an explosion-risk area zone (gas) 1 and 2, the following applies:



DANGER!

Risk of explosion caused by electrostatic charge.

In the event of a sudden discharge from electrostatically charged devices or individuals, there is a risk of an explosion in the explosion-risk area.

- ▶ Take suitable measures to ensure that no electrostatic discharges can build up in the explosion-risk area.
- ▶ Clean the device surface by gently wiping it with a damp or anti-static cloth only.

4.1.2 Media in explosion-risk areas



If explosive media are used, this can result in additional explosion risks.

4.1.3 Actuators / valves in explosion-risk areas



Use in an explosive atmosphere may be restricted by the actuators / valves. Observe the operating instructions of the actuators / valves.

4.1.4 Cleaning in explosion-risk areas



Check that any cleaning agents are approved for use in explosive atmospheres.

4.1.5 Adhesive signs for explosion-risk areas

Sign




Fig. 2: Sign

Approval sticker




Fig. 3: Example approval sticker

4.1.6 Temperature ranges in explosion-risk areas

Ambient temperature

Type 8697 PX03 (3 GD (tcnA))	0 – + 55 °C
Type 8697 PE99 (2 GD)	0 – + 55 °C ¹⁾
Type 8697 PE51 (2 G with pilot valve)	-10 – +55 °C ¹⁾
Type 8697 PE51 (2 G without pilot valve)	-20 – +60 °C

4.1.7 Electrical data PE99 and PE51

The device in ignition degree of protection intrinsic safety Ex ia IIC/IIIC (PE99 and PE51) may be connected only to intrinsically safe electric circuits.

Explosion group	IIC/IIIC
Category	ia
Temperature class	T4 / 135 °C

¹⁾ The maximum ambient temperature may be restricted by the maximum allowable input power P_i of the pilot valve (see "Tab. 1: Value pairs input voltage - input current" on page 9).

The electric circuits have the following parameter:

Electric circuit limit switch

Upper end position: Terminals INI Top 1 +/-

Lower end position: Terminals INI BTM 1 +/-

Each:

Max. allowable input voltage (Ui) 20 V

Max. allowable input current (Ii) 60 mA

Max. allowable input power (Pi) 200 mW

Max. inner capacitance (Ci) 178 nF

Max. inner inductance (Li) 66 µH

Electric circuit pilot valve

Pilot valve 1: Terminals VALVE +/-

Max. allowable input voltage Ui and input current Ii
(use only value pairs that are displayed one below the other)

Voltage value [V] = Ui	15	18	20	22	25	28	30	35
Current value [A] = Ii	0.9	0.44	0.309	0.224	0.158	0.120	0.101	0.073

Tab. 1: Value pairs input voltage - input current

Max. allowable input power Pi

Number of pilot valves	Max. allowable output Pi	Max. ambient temperature Type 8697	
		PE99	PE51
0	-	+55 °C	+60 °C
1	0.7 W	+55 °C	+55 °C
1	1.1 W	+50 °C	+50 °C

Tab. 2: Max. allowable input power

Max. inner capacitance (Ci) negligible

Max. inner inductance (Li) negligible

4.2 Installation locking wire for PE99 and PX03



DANGER!

Risk of explosion when opening the device.

- ▶ Open device only when no Ex atmosphere is present.
- ▶ Prior to start-up, secure the transparent cap against being opened without tools by using the enclosed locking wire.




Fig. 4: Installation locking wire

Procedure:

- Push locking wire through the bore of the transparent cap.
- Push locking wire through fastening element and pull it tight.
- Tighten the screw on the fastening element.

4.3 Adaption set - installation note



DANGER!

Risk of explosion if incorrect adaption set is used.

- ▶ Only use suitable adaption set.



The degree of protection required for ignition degree of protection intrinsic safety "i", is only guaranteed in connection with suitable adaption sets.

Attachment	Adaption set series
FA03	ELEMENT
FA05	Classic

Tab. 3: Attachment and adaption set



The order designations for the adaption sets can be found in the "Order table adaption sets" in the data sheet for Type 8697.

Attachment FA03




Fig. 5: Attachment FA03

Attachment FA05




Fig. 6: Attachment FA05

4.4 Explosion protection approval

The explosion protection approval is only valid if you use the modules and components authorized by Bürkert, as described in these operating instructions.

If you make unauthorized changes to the system, the modules or components, the explosion protection approval will be terminated.

EC-type examination certificates

BVS 13 ATEX E104X and
IECEx BVS 13.0105X,

BVS 13 ATEX E087X and
IECEx BVS 13.0097X were issued by

DEKRA EXAM GmbH
Dinnendahlstraße 9
D-44809 Bochum

The PTB (CE0102) audits the manufacture.

www.burkert.com