

Type LFPC 8763 CANopen

Object Description

Content

1	Overview	3
2	Objects.....	4
2.1	Cyclic data.....	4
2.2	Acyclic data	8

1 Overview

Used datatypes:

Unsigned8	8 bit: unsigned integer
Unsigned16	16 bit: unsigned integer
Unsigned32	32 bit: unsigned integer
REAL32	32 bit: float value IEEE 754
Visible String	Character string

2 Objects

2.1 Cyclic data

Object 0x2500 – Pressure

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	7	x		
0x01	Pressure	REAL32	0	x		x
0x02 - 0x07	Internal settings			x		

Description of the subindexes

Value: cyclic output for Pressure value

Internal settings: for internal use only

Object 0x2501 Temperature

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	7	x		
0x01	Temperature	REAL32	0	x		x
0x02 - 0x07	Internal settings			x		

Description of the subindexes

Value: cyclic output for Temperature value

Internal settings: for internal use only

Object 0x2503 In Ch1

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	7	x		
0x01	In Ch1 Scaled Input	REAL32	0	x		x
0x02 - 0x07	Internal settings			x		

Description of the subindexes

Value: cyclic output of user scaled analog input value of input 1

Internal settings: for internal use only

Object 0x2503 In Ch2

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	7	x		
0x01	In Ch2 Scaled Input	REAL32	0	x		x
0x02 - 0x07	Internal settings			x		

Description of the subindexes

Value: cyclic output of user scaled analog input value of input 2

Internal settings: for internal use only

Object 0x2504 Valve Control

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	7	x		
0x01	Valve Control	REAL32	0	x		x
0x02 - 0x07	Internal settings			x		

Description of the subindexes

Value: cyclic output of the duty cycle applied to control or exhaust valve. Positive value indicate Control valve is driven; negative values indicate exhaust valve is driven.

Internal settings: for internal use only

Object 0x2505 Pump Control

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	7	x		
0x01	Valve Control	Unsigned8	0	x		x
0x02 - 0x07	Internal settings			x		

Description of the subindexes

Value: cyclic output of the DO1 state

Internal settings: for internal use only

Object 0x2506 TTL

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	7	x		
0x01	Valve Control	Unsigned8	0	x		x
0x02 - 0x07	Internal settings			x		

Description of the subindexes

Value: cyclic output of the DO2 state

Internal settings: for internal use only

Object 0x2508 In Ch1 Input Value

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	7	x		
0x01	In Ch1 Input Value	REAL32	0	x		x
0x02 - 0x07	Internal settings			x		

Description of the subindexes

Value: cyclic output of physical input at input 1. Scaled to selected unit (v or A)

Internal settings: for internal use only

Object 0x2509 In Ch2 Input Value

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	7	x		
0x01	In Ch2 Input Value	REAL32	0	x		x
0x02 - 0x07	Internal settings			x		

Description of the subindexes

Value: cyclic output of physical input at input 2. Scaled to selected unit (v or A)

Internal settings: for internal use only

Object 0x250A Control Deviation

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	7	x		
0x01	Control Deviation	REAL32	0	x		x
0x02 - 0x07	Internal settings			x		

Description of the subindexes

Value: cyclic output Control Deviation

Internal settings: for internal use only

Object 0x250B Setpoint

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	7	x		
0x01	Setpoint	REAL32	0	x		x
0x02 - 0x07	Internal settings			x		

Description of the subindexes

Value: cyclic output used set point value

Internal settings: for internal use only

Object 0x250B Namur Status

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	7	x		
0x01	Namur Status	Unsigned8	0	x		x
0x02-0x07	Internal settings			x		

Description of the subindexes

Value: cyclic output of NAMUR status

Internal settings: for internal use only

Object 0x2540 Pressure Setpoint

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	7	x		
0x01	Pressure Setpoint	REAL32	0	x	x	x
0x02-0x07	Internal settings			x		

Description of the subindexes

Value: cyclic input for Pressure Setpoint

Internal settings: for internal use only

Object 0x2541 Pump Setpoint

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	7	x		
0x01	Pump Setpoint	Unsigned8	0	x	x	x
0x02-0x07	Internal settings			x		

Description of the subindexes

Value: cyclic input for Pump Setpoint (DO1)

Internal settings: for internal use only.

Object 0x254C Valve Setpoint

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	7	x		
0x01	Valve Setpoint	REAL32	0	x	x	x
0x02-0x07	Internal settings			x		

Description of the subindexes

Value: cyclic input for Valve Setpoint

Internal settings: for internal use only

2.2 Acyclic data



The standard objects are described in separate operating instruction:
www.burkert.com → Type 8763 “CANopen Network configuration”
 The device specific objects are described below

Object 0x200A Power Supplyalarm Values

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	5	x		
0x01	Voltage error limit high	Real32	26.4	x		
0x02	Voltage error limit low	Real32	21.6	x		
0x05	Voltage hysteresis	Real32	1.0	x		

Description of the subindexes

Voltage error limit high: Limit value supply voltage, error message when exceeded
 Voltage error limit low: Limit value supply voltage, error message when undercut
 Voltage hysteresis: Tolerance range upper and lower limit value supply voltage

Object 0x200B Temperature Alarm Values

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	5	x		
0x01	Temperature error limit high	Real32	363.15	x		
0x02	Temperature error limit low	Real32	258.15	x		
0x05	Temperature hysteresis	Real32	2.0	x		

Description of the subindexes

Temperature error limit high: Limit value device temperature, error message when exceeded
 Temperature error limit low: Limit value device temperature, error message when undercut
 Temperature hysteresis: Tolerance range upper and lower limit value device temperature

Object 0x2C00 Device

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	0	x		
0x01	Variant	Unsigned8	1	x		

Description of the subindexes

Variant: Device variant.0: Digital variant, 1: Analog variant

Object 0x2C11 Pressure Sensor

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	6	x		
0x01	Temperature Filter Response Time	REAL32	0	X	X	
0x02	Pressure Filter Response Time	REAL32	0	X	X	

Description of the subindexes

Temperature Filter Response Time: response time of filter in second. 0 means inactive.

Pressure Filter Response Time: response time of filter in second. 0 means inactive.

Object 0x2C13 AMS 5812

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	6	x		
0x01	Minimum Pressure	REAL32		x		
0x02	Maximum Pressure	REAL32		x		

Description of the subindexes

Minimum Pressure: sensor minimum allowed pressure

Maximum Pressure: sensor maximum allowed pressure

Object 0x2C21 Controller

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	10	x		
0x01	Kp	REAL32		x	x	
0x02	Ki	REAL32		x	x	
0x03	Kd	REAL32		x	x	
0x08	Deadband	REAL32		x	x	
0x0A	Cutoff	REAL32		x	x	

Description of the subindexes

Kp: Controller proportional part

Ki: controller integral part

Kd: Controller derivative part

Deadband: insensitivity range of controller in percent of maximum pressure

Cutoff: sealing function of valve (If controller output below this value, valve is closed tightly)

Object 0x2C22 Setpoint Handling

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	6	x		
0x01	State	Unsigned8	0	x		
0x02	Setpoint Source	Unsigned8	0	x	x	
0x04	Fixed Setpoint	REAL32	0	x	x	
0x05	Manual Setpoint	REAL32	0	x	x	
0x06	Rise Time	REAL32	0,2	x	x	

Description of the subindexes

State: State of set point handling (0: error, 1: closed loop control, 2: exhaust, 3: open loop control)

Setpoint Source: Used set point Source (0: bÜS, 1: fixed, 2: manual, 3: open loop, 4: Analog Input 1, 5: Analog input 2)

Fixed Setpoint: Value used as set point if fixed set point source selected

Manual Setpoint: Value used as set point if manual set point source selected

Rise Time: rise time of pre-filter for set point value in seconds to limit dynamics of set point jumps

Object 0x2C31 Control Valve

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	8	x		
0x02	Manual Setpoint	REAL32		x		
0x07	Current Value	REAL32		x		
0x08	Nominal Width	REAL32		x		

Description of the subindexes

Manual Setpoint currently active duty cycle, which is applied to valve

Current Value: current consumption of valve

Nominal Width: valve nominal width

Object 0x2C32 Exhaust Valve

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	8	x		
0x02	Manual Setpoint	REAL32		x		
0x07	Current Value	REAL32		x		
0x08	Nominal Width	REAL32		x		

Description of the subindexes

Manual Setpoint currently active duty cycle, which is applied to valve

Current Value: current consumption of valve

Nominal Width: valve nominal width

Object 0x2C34 Pump Task

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	8	x		
0x01	Setpoint Source	Unsigned8	0	x	x	
0x02	Value Pump On Analog Source Physical	REAL32	0	x	x	
0x03	Value Pump Off Analog Source Physical	REAL32	0	x	x	
0x04	Value Pump On Analog Source Scaled	REAL32	0	x	x	
0x05	Value Pump Off Analog Source Scaled	REAL32	0	x	x	

Description of the subindexes

Setpoint Source: set point source used for DO1 (0: off, 1: on, 2: analog threshold, 3: analog threshold scaled, 4: bÜS)

Value Pump On Analog Source Physical: DO1 will turn on if physical input at AI1 goes below this value

Value Pump Off Analog Source Physical: DO1 will turn off if physical input at AI1 goes above this value

Value Pump On Analog Source Scaled: DO1 will turn on if scaled input at AI1 goes below this value

Value Pump Off Analog Source Scaled: DO1 will turn off if physical input at AI1 goes above this value

Object 0x2D00 In Channel 1

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	15	x		
0x01	Type	Unsigned8	1	x		
0x02	Config Mode	Unsigned8				
0x03	Mode Name	Visible String				
0x06	Low Point	REAL32				
0x07	High Point	REAL32				
0x08	Filter Response Time	REAL32				
0x0C	Raw Unit	Unsigned32				
0x0F	Percent	REAL32				

Description of the subindexes

Type: Type of input (1: Analog input)
 Config Mode: Configuration of input mode (0: not configured, 1: 4-20mA, 3: 0-10V)
 Mode Name: Name of mode (either 4-20mA or 0-10V)
 Low Point: Low point for user scaling
 High Point: High point for user scaling
 Filter Response Time: Input filter response time in second
 Raw Unit: CANopen unit of selected input type (mA or V)
 Percent: Input value scaled to percent

Object 0x2D00 In Channel 2

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	15	x		
0x01	Type	Unsigned8	1	x		
0x02	Config Mode	Unsigned8		x	x	
0x03	Mode Name	Visible String		x		
0x06	Low Point	REAL32		x	x	
0x07	High Point	REAL32		x	x	
0x08	Filter Response Time	REAL32		x	x	
0x0C	Raw Unit	Unsigned32		x		
0x0F	Percent	REAL32		x	x	

Description of the subindexes

Type: Type of input (1: Analog input)
 Config Mode: Configuration of input mode (0: not configured, 1: 4-20mA, 3: 0-10V)
 Mode Name: Name of mode (either 4-20mA or 0-10V)
 Low Point: Low point for user scaling
 High Point: High point for user scaling
 Filter Response Time: Input filter response time in second
 Raw Unit: CANopen unit of selected input

Object 0x2CD02 Binary Out

Sub-Index	Name	Data type	Default	Access		PDO mappable
				Read	Write	
0x00	Number Of Entries	Unsigned8	4	x		
0x01	Active	Unsigned8		x	x	
0x02	Polarity	Unsigned8		x	x	
0x03	Threshold	REAL32		x	x	
0x04	Hysteresis	REAL32		x	x	

Description of the subindexes

Active: set DO2 active

Polarity: Polarity for DO2

Threshold: Threshold, if control deviation in % full scale pressure range goes below this value, DO1 is set to polarity

Hysteresis: Value that needs to be overcome to set from on to of